INSTITUTE OF HEALTH SCIENCES

(A Unit of Margdarsi)

Office: N-2/41, I.R.C Village, Nayapalli, Bhubaneswar – 751015, Ph.:0674-2553640, 2550054

Campus: Chandaka, Bhubaneswar, Khordha, Odisha, pin: 754005, E-mail:ihsbbsr@margdarsi.org, web: www.ihsindia.org



Vehicles 131

Sl	Vehicle no	Status	Action taken	Remarks
	Date: 20/7/2023			
1	OR 02 AS 2376	Fitness expired need repairing before fitness	Bus Sent to Garage for body repairing all electrical Parts check.	Now the Vehicle is ready for fitness
	Date: 15/11/2023			
2	OR 02 AZ 682	Fitness expired need to repairing before fitness	Bus Sent to Garage for body & Electrical lights repairing	Now the Bus is ready for fitness
	Date: 14/12/2023			
3	OR 02 AV 1385	Fitness expired need to repairing before fitness	Bus Sent to garage for body repairing & electrical lights repairing	Now the Bus is ready for fitness
	Date: 22/4/2024			
	OR 02 AS 2376	Go to RTO	Got fitness certificate	ok
	OR 02 AV 1385	Go to RTO	Got fitness certificate	ok
	OR 02 AZ 682	Go to RTO	Got fitness certificate	ok



Dept	Description	Action taken	Status
	Date: 20/05/2022		
1	All the open well are cleaning requirement	One in house team to prepare the cleaning of open well water & Scraping are of the well	One team execute the water & Scraping are of the well Properly
	Date: 08/08/2023		
2	Dining block & Girls School Aquaguard Machine not Working	Call to the Service Provider to repairing of both the machine	The Service Provider's are came & repairing both the machine
	Date: 12/8/23		
3	Admin Block Aqua guard have not Working Properly.	Our in house Staff have inspected & identifying the Purifier Candle are Damaged need to be changed.	After that both the Candle are replaced & Right now the aqua guard is working Properly.
	Date: 19/12/23		
4	Academic Block Aqua guard not Working	The responsible staff have inspected & identifying the filter filter Candle is Damaged	A new Candle is replaced & task Completed



Electricals 11

Sl	Description	Status	Action taken	Remarks
	Date: 20/6/23			
1	IPD Block 4 Wiring of Electrical line for installation of Treatment machinery	15 Amp – 4 nos Switch & Socket 32Th Switch and & Cable required	Send the required new materials for installation by Store	installation Successfully Completed
	Date: 15/7/23			
2	Auditorium: Separation of Main Connection in case auditorium. Split A/c & light Connection	Both A/c & light are in same phase. There is a Problem exist at the time of Power	In Panel put Split the A/c & lights for smooth functioning	done
	Date: 8/10/23			
3	Servicing of Generator	D.G. Set need to be servicing change of oil filter air & diesel filter & Engine oil and General checkup	Placed servicing request to Company Service Center	the Service man come to Company & Complete the Work
	Date: 22/11/23			
4	Admin Block 1st floor Electrical new wiring	all the materials are Purchased for new Electrical wiring of 1st floor of Admin Block	Our inhouse Electricians have done the wiring in time	Task completed
5	Transformer motor not working	A Complained raised to Dept. for change the	the Electrical dept have come and exchange the	Task Completed



Director
Institute of Health Sciences
Bhubaneswar